



Single Window Clearance System

Directorate of Industries(DOI)
Govt. of Himachal Pradesh

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

NO OBJECTION CERTIFICATE

TO WHOM IT MAY CONCERN

That the premises of **Sai Ram International School Society, Vill. Manguwal, P.O. Bhatian, Teh. Nalagarh, Distt. Solan, H.P.** was inspected on 2021-06-15 with reference to his application No. App/05/04/21/8/884 dated 2021-05-04 19:06:20 by the incharge Fire Station FS Nalagarh with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years w.e.f. **18/06/2021 to 17/06/2023** subject to fulfilment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire services.
4. Good House keeping must be maintained within the premises.

Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.

A. Sharma

[Digitally Signed 18-06-2021 13:48:42]

Chief Fire Officer.
Himachal Pradesh Shimla-2

Place: Shimla

Dated: 2021-06-18



EKOMKAR FIRE PROTECTION

FIRE & SAFETY EQUIPMENTS

Saner Kharuni, Tehsil. Baddi, Distt. Solan (H.P.) 173205

E-mail : ekomkarfireprotection@gmail.com



E F P

Ref. No. 1099 EKM **Fire Emergency mock drill Report** Date 17/12/2022

Area & Location: M/s Sai Ram International School, Manguwal

Sarika Sharma, Manguwal, Po-Rajpura,

Tehsil-Nalagarh Dist-Solan (H.P)-174101,

Land Mark:-Near Shiv Mandir Manguwal

Mock Drill Dated: 17/12/2022 & Time:-10.30 AM to 11.30 AM

Following observations were noted during conduct of Fire Emergency mock drill.

Observers

1. Kavita Kundra (Headmitress)
2. Shrfali (Teacher)
3. Rajni Rajput (Teacher)
4. Nisha (Acc.)
5. Saurabh(Teacher)
6. Rajni Thakur (Teacher)
7. Neha Jamwal (Teacher)
8. Neha Thakur (Teacher)
9. Class 9th, 8th
10. Drivers
11. Attendants

Mock Drill Conducted By:-

1. Jaipal Thakur & Team (Fire officer Nalagarh)
2. Sunny Saini (Prop:-Ekomkar Fire Protection)

Positive Notes:

All the workmen and staff reported to the Assembly point without any panic.

The evacuation was performed successfully well in time.

Communication was well enough to reach the Fire Point at the right time.

Ekomkar Fire Protection

Sunny Saini
Proprietor

The fire-Fighting team used the right Extinguisher for the Extinguishing purpose (DCP, Water)

EKOMKAR FIRE PROTECTION

Address: Village- Kharuni Sanerh, Tehsil- Baddi, Distt. Solan (H.P) 174101.
M.No-97363-15027 GST-02INTPK4417H1ZS

- 15.Previous totalltime :
16.Deficiency observed during the exercise :
17.Action recommended for improvement:
18.Name of person responsible to follow up, above: -
19.Other remarks:

Ekomkar Fire Protection


Proprietor

EKOMKAR FIRE PROTECTION

Address: Village- Kharuni Sanerh, Tehsil- Baddi, Distt. Solan (H.P) 174101.
M.No-97363-15027 **GST-02INTPK4417H1ZS**

ERT member has done well and evacuate the Work Location on time.

Emergency Vehicle is available at Site.

The workforce remains calm, while the mock drill was in progress, and showed keen interest to get knowledge about the emergency.


Workers were briefed about the emergency response procedure and fire Emergency.

The evacuation team response was quick.

GUIDELINES TO FOLLOW FOR EMERGENCY SITUATION

Particulars	During mock drills the following points should be listed and checked
Emergency Response Plan	Emergency Response Plan is available (its contain and action Plan for ready reference)
Communication or public address system	Communication or public address system were used
First aid kit & aider	First aid boxes and its contents are available at site.
Assembly Place	Designated Assembly place Available at Cooling Tower Site.
Audio alarm system	Audio alarm/Handheld megaphone available.
Evacuation Plan	Minimum action identified and completed before Evacuation(People to be evacuated from the Emergency site)
Others	Preparedness and alertness Involvement of people during emergencies.

Eekomkar Fire Protection


Proprietor